

# Energy performance certificate (EPC)

91 SCARISBRICK NEW ROAD  
SOUTHPORT  
PR8 6LR

Energy rating

F

Valid until 1 March 2031

Certificate number

0229-0004-2207-8809-1200

## Property type

Detached house

## Total floor area

200 square metres

## Rules on letting this property



## You may not be able to let this property


This property has an energy rating of F. It cannot be let, unless an exemption has been registered. You can read [guidance for landlords on the regulations and exemptions](https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance) (<https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance>).

Properties can be rented if they have an energy rating from A to E. The [recommendations section](#) sets out changes you can make to improve the property's rating.

## Energy efficiency rating for this property

This property's current energy rating is F. It has the potential to be C.

[See how to improve this property's energy performance.](#)



The graph shows this property’s current and potential energy efficiency.

Properties are given a rating from A (most efficient) to G (least efficient).

Properties are also given a score. The higher the number the lower your fuel bills are likely to be.

The average energy rating and score for a property in England and Wales are D (60).

Breakdown of property’s energy performance

This section shows the energy performance for features of this property. The assessment does not consider the condition of a feature and how well it is working.

Each feature is assessed as one of the following:

- very good (most efficient)
- good
- average
- poor
- very poor (least efficient)

When the description says “assumed”, it means that the feature could not be inspected and an assumption has been made based on the property’s age and type.

Feature	Description	Rating
Wall	Cavity wall, as built, no insulation (assumed)	Poor
Roof	Pitched, 50 mm loft insulation	Poor
Window	Single glazed	Very poor
Main heating	Boiler and radiators, mains gas	Average
Main heating control	Programmer, no room thermostat	Very poor

Feature	Description	Rating
Hot water	From main system, no cylinder thermostat	Poor
Lighting	Low energy lighting in 50% of fixed outlets	Good
Floor	Suspended, no insulation (assumed)	N/A
Secondary heating	None	N/A

## Primary energy use

The primary energy use for this property per year is 506 kilowatt hours per square metre (kWh/m<sup>2</sup>).

► [What is primary energy use?](#)

### Environmental impact of this property

One of the biggest contributors to climate change is carbon dioxide (CO<sub>2</sub>). The energy used for heating, lighting and power in our homes produces over a quarter of the UK's CO<sub>2</sub> emissions.

### An average household produces

6 tonnes of CO<sub>2</sub>

### This property produces

18.0 tonnes of CO<sub>2</sub>

### This property's potential production

4.5 tonnes of CO<sub>2</sub>

By making the [recommended changes](#), you could reduce this property's CO<sub>2</sub> emissions by 13.5 tonnes per year. This will help to protect the environment.

Environmental impact ratings are based on assumptions about average occupancy and energy use. They may not reflect how energy is consumed by the people living at the property.

## How to improve this property's energy performance

Making any of the recommended changes will improve this property's energy efficiency.

If you make all of the recommended changes, this will improve the property's energy rating and score from F (29) to C (80).

► [What is an energy rating?](#)



---

### Recommendation 1: Increase loft insulation to 270 mm

Increase loft insulation to 270 mm

**Typical installation cost**

£100 - £350

---

**Typical yearly saving**

£156

---

**Potential rating after carrying out recommendation 1**

31 | F

---

### Recommendation 2: Cavity wall insulation

Cavity wall insulation

**Typical installation cost**

£500 - £1,500

---

**Typical yearly saving**

£532

---

**Potential rating after carrying out recommendations 1 and 2**

41 | E

---

### Recommendation 3: Floor insulation (suspended floor)

Floor insulation (suspended floor)

**Typical installation cost**

£800 - £1,200

---

Typical yearly saving	£218
Potential rating after carrying out recommendations 1 to 3	45   E

## Recommendation 4: Hot water cylinder insulation

Increase hot water cylinder insulation	
Typical installation cost	£15 - £30
Typical yearly saving	£27
Potential rating after carrying out recommendations 1 to 4	46   E

## Recommendation 5: Draught proofing

Draught proofing	
Typical installation cost	£80 - £120
Typical yearly saving	£60
Potential rating after carrying out recommendations 1 to 5	47   E

## Recommendation 6: Low energy lighting

Low energy lighting	
Typical installation cost	£20
Typical yearly saving	

Potential rating after carrying out recommendations 1 to 6

48 | E

Recommendation 7: Heating controls (room thermostat and TRVs)

Heating controls (room thermostat and TRVs)

Typical installation cost £350 - £450

Typical yearly saving £255

Potential rating after carrying out recommendations 1 to 7

53 | E

Recommendation 8: Replace boiler with new condensing boiler

Condensing boiler

Typical installation cost £2,200 - £3,000

Typical yearly saving £839

Potential rating after carrying out recommendations 1 to 8

72 | C

Recommendation 9: Double glazed windows

Replace single glazed windows with low-E double glazed windows

Typical installation cost £3,300 - £6,500

Typical yearly saving

£114

Potential rating after carrying out recommendations 1 to 9

74 | C

## Recommendation 10: Solar photovoltaic panels, 2.5 kWp

Solar photovoltaic panels

Typical installation cost

£3,500 - £5,500

Typical yearly saving

£342

Potential rating after carrying out recommendations 1 to 10

80 | C

## Paying for energy improvements

[Find energy grants and ways to save energy in your home. \(https://www.gov.uk/improve-energy-efficiency\)](https://www.gov.uk/improve-energy-efficiency)

Estimated energy use and potential savings

Estimated yearly energy cost for this property

£3398

Potential saving

£2247

The estimated cost shows how much the average household would spend in this property for heating, lighting and hot water. It is not based on how energy is used by the people living at the property.

The estimated saving is based on making all of the recommendations in [how to improve this property's energy performance](#).

For advice on how to reduce your energy bills visit [Simple Energy Advice \(https://www.simpleenergyadvice.org.uk/\)](https://www.simpleenergyadvice.org.uk/).

## Heating use in this property

Heating a property usually makes up the majority of energy costs.

Estimated energy used to heat this property

## Space heating

36627 kWh per year

---

## Water heating

3989 kWh per year

---

## Potential energy savings by installing insulation

Type of insulation	Amount of energy saved
--------------------	------------------------

Loft insulation	2060 kWh per year
-----------------	-------------------

---

Cavity wall insulation	7031 kWh per year
------------------------	-------------------

You might be able to receive [Renewable Heat Incentive payments \(https://www.gov.uk/domestic-renewable-heat-incentive\)](https://www.gov.uk/domestic-renewable-heat-incentive). This will help to reduce carbon emissions by replacing your existing heating system with one that generates renewable heat. The estimated energy required for space and water heating will form the basis of the payments.

## Contacting the assessor and accreditation scheme

This EPC was created by a qualified energy assessor.

If you are unhappy about your property's energy assessment or certificate, you can complain to the assessor directly.

If you are still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation schemes are appointed by the government to ensure that assessors are qualified to carry out EPC assessments.

## Assessor contact details

### Assessor's name

David Roskell

---

### Telephone

07850377311

---

### Email

[david@4dhr.com](mailto:david@4dhr.com)

---

## Accreditation scheme contact details

### Accreditation scheme

Stroma Certification Ltd

---

### Assessor ID

STRO017167

---



**Telephone**

0330 124 9660

---

**Email**

[certification@stroma.com](mailto:certification@stroma.com)

---

**Assessment details****Assessor's declaration**

No related party

---

**Date of assessment**

2 March 2021

---

**Date of certificate**

2 March 2021

---

**Type of assessment**

► [RdSAP](#)

---

**Other certificates for this property**

If you are aware of previous certificates for this property and they are not listed here, please contact us at [mhclg.digital-services@communities.gov.uk](mailto:mhclg.digital-services@communities.gov.uk), or call our helpdesk on 020 3829 0748.

**Certificate number**

[0580-2837-6022-9609-4071 \(/energy-certificate/0580-2837-6022-9609-4071\)](/energy-certificate/0580-2837-6022-9609-4071)

**Valid until**

**6 February 2021 (Expired)**

---